



# Certificate of Compliance

**Certificate:** 80047012

**Master Contract:** 301034

**Project:** 80047012

**Date Issued:** 2020-10-06

**Issued To:** Cavicondor S.p.A.  
C.da Barriera Bivio Nasserò sn  
Belpasso, Catania, 95032  
Italy

**Attention:** Tony Turchi

*The products listed below are eligible to bear the CSA Mark shown*

**Issued by:** *Edward Lourenco*  
Edward Lourenco



## **PRODUCTS**

CLASS 5851-01 WIRES Appliance

AWM, class I/II, group A/B rated 90C (-15C), 600V, FT1; optional: -20/-30/-40C. Multi-conductor round construction. Number of conductors: 02 or more. Size range (AWG or kcmil): 30-2000. Insulation: PVC. Covering: optional, PVC, Shield: optional, metallic braid. Jacket: PVC.

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 210-15 Appliance Wiring Material Products

## **MARKINGS**

See descriptive reports.



## *Supplement to Certificate of Compliance*

**Certificate:** 80047012

**Master Contract:** 301034

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80047012	2020-10-06	Original certification of AWM, class I/II, group A/B rated 90C (-15C), 600V, FT1; optional: -20/-30/-40C. Multi-conductor round construction. Number of conductors: 02 or more. Size range (AWG or kcmil): 30-2000. Insulation: PVC. Covering: optional, PVC, Shield: optional, metallic braid. Jacket: PVC.