Cavicondor S.p.A. Società con socio unico Fax +39 0957563000 C.da Barriera Bivio Nassero sn www.cavicondor.eu 95032 Belpasso (CT) Cap. Sociale: € 2.400.000 i.v.

Tel. +39 0957563011 info@cavicondor.eu Iscritta alla C.C.I.A.A. di Catania 04901700874

REA: 328474 Codice Fiscale e Partita Iva: 04901700874 Iscrizione Registro Imprese:

## **DECLARATION OF PERFORMANCE (DoP)**

N. 002/24

Unique identification code of the product type:

FG17 450/750 V

Intended uses:

Electrical cable for general applications in construction subject to fire reaction requirements

Manufacturer:

CAVICONDOR S.p.A. C.da Barriera - Bivio Nassero sn 95032 Belpasso (CT) ITALY Email: info@cavicondor.eu

System AVCP:

1+

Harmonised standard:

EN 50575:2014+A1:2016

Notified body:

N° 0987 LAPI LABORATORIO PREVENZIONE INCENDI S.p.A.

Declared performance

Reaction to fire: Cca s1b,d1,a1 Release of dangerous substances: NPD

The performance of the product identified above is in conformity with the set of declared performances.

This declaration of perfomance issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Belpasso (CT) Date of emission: 19/04/2024

Signed for and on behalf of the manufacturer by:

Cavicondor S.p.A. - Ufficio Tecnico/Laboratorio C.Q.